WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40694
Permit No.
Basin 212

NOTICE OF INTENT NO. 11377

1. OWNER Cal Neu Pipe Line
MAILING ADDRESS C/o Converse Consultants 4670 S. Polaris Ave, Las Vegas
ADDRESS AT WELL LOCATION NW Corner of Valley View & Hacienda.

2. LOCATION SE ¼ NE ¼ Sec. 30 T. 21 N/S R. 61 E Clark County
PERMIT NO. MO-2238 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0	.5	.5
Silty Sand w/gravel		.5	4	3.5
fine gravelly Sand				
Partially cemented		4	6	2
Caliches		6	11	5
gravelly Sand				
partially cemented		11	17	6
Silty sand w/ trace				
fine gravel		17	20	3
Silty Sand w			40	20
Some fine gravel		20	~~25~~	~~5~~
fine gravelly Sand		40	44	4
gravelly sand		44	47	3
Caliches - cobbles		47	51	14
fine gravel w/clay		51	60	9
Sandy clay w/				
fine gravel		60	72	12
T.D = 72'				

RECEIVED
MAR 10 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 2-11, 1993
Date completed 2-11, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 72 Feet Depth Cased 70 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 ¼ Inches	0 Feet	72 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	.7 lbs	SCH. 40	0	70

Perforations:
Type perforation factory slotted
Size perforation 0.020
From 40 feet to 70 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-26 / 24-26 Bent.
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout w/ Bent.
Gravel Packed: ☑ Yes ☐ No
From 26 feet to 72 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Wilson Contractor
Address 4670 S. Polaris Ave. Contractor
Las Vegas NV. 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller
Signed By driller performing actual drilling on site or contractor
Date 3-2-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627