

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23653

1. OWNER LAS VEGAS PAVING CORP. ADDRESS AT WELL LOCATION WATER VISTA  
 MAILING ADDRESS 3401 N. 5TH ST. SOUTH OF SUNFLOWER  
N. LV. NV. 89030  
 2. LOCATION 1/4 Sec. 29 T. 21 N. 62 (E) Clark County  
 PERMIT NO. DW1010 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other BUCKET RIT

6. LITHOLOGIC LOG

Well #	Material	Water Strata	From	To	Thick-ness
	Road Bed		0	2	2
	Sandy Clay		2	6	4
	Sand		6	10	4
	Sand & Gravel		10	20	10
	Sandy Clay with Gravel		20	40	20

8. WELL CONSTRUCTION  
 Depth Drilled 40 Feet Depth Cased 40 Feet  
 HOLE DIAMETER (BIT SIZE)  
24" From 0 To 40 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12"</u>			<u>0</u>	<u>40</u>

Perforations:  
 Type perforation SAW CUT  
 Size perforation .040  
 From 20 feet to 40 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 0 feet to 40 feet

9. WATER LEVEL  
 Static water level 12 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Fast Hills Eng. Contractor  
 Address 309 E 3RD ST. Contractor  
CORONA CAL.  
 Nevada contractor's license number \_\_\_\_\_  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1567  
 Signed Cluck W. Sewell  
 By driller performing actual drilling on site or contractor  
 Date 3-10

Date started 3-10, 1993  
 Date completed 3-10, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

RECEIVED  
 MAR 10 1993

Div. of Water Resources  
 Branch Office - Las Vegas, NV