WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40706
Permit No.
Basin 212

NOTICE OF INTENT NO. 23652

1. OWNER LAS VEGAS PAVING
MAILING ADDRESS 3401 N. 5TH ST. N LV NV 89030
ADDRESS AT WELL LOCATION MOUNTAIN VISTA AT I 95 OVERPASS

2. LOCATION ¼ ¼ ¼ Sec 29 T 21 N(S) R 62 E CLARK County
PERMIT NO. Dw 1010 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE (DEWATERING)
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other BUCKET

6. LITHOLOGIC LOG

Well 3

Material	Water Strata	From	To	Thickness
Road Red		0	2	2
Sandy Clay		2	12	10
White Clay w/Gravel		12	20	8
Red Clay w/Gravel		20	40	20

RECEIVED
MAR 15 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 3-11, 1993
Date completed 3-11, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
24"	0	40

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12			0	40

Perforations:
Type perforation SAW CUT
Size perforation .040
From 20 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 40 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Foot Hills Eng. (Contractor)
Address 905 E. 3RD ST (Contractor)
CORONA Cal.
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1567
Signed Chuck Sewell (By driller performing actual drilling on site or contractor)
Date 3-24

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627