

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23612

1. OWNER LAS VEGAS PAVERS ADDRESS AT WELL LOCATION Mountain Vista  
 MAILING ADDRESS 3401 N 5th St. N LV NV 89030 at E 9500 E Pass

2. LOCATION 1/4 Sec. 28 T 21 NR 62 E Clark County

PERMIT NO. 021010 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other BUCKET

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>ROAD BED</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>SANDY CLAY</u>		<u>2</u>	<u>8</u>	<u>6</u>
<u>Red CLAY</u>		<u>8</u>	<u>12</u>	<u>4</u>
<u>White Clay w/gravel</u>		<u>15</u>	<u>40</u>	<u>25</u>

8. WELL CONSTRUCTION  
 Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
24" Inches 0 Feet 40 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12</u>			<u>0</u>	<u>40</u>

Perforations:  
 Type perforation SAW CUT  
 Size perforation 1.040  
 From 30 feet to 40 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 0 feet to 40 feet

9. WATER LEVEL  
 Static water level 15 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 3-12, 1997  
 Date completed 3-12, 1997

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Foot Hills Eng.  
 Address 905 E. 3rd St. Corona Cal.  
 Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1567  
 Signed Chuck Sewell  
 By driller performing actual drilling on site or contractor  
 Date 3-14

RECEIVED  
 MAR 15 1993  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV