WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46710
Permit No.
Basin 162

NOTICE OF INTENT NO. 11586

1. OWNER Dale Cain
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION NE ¼ SW ¼ Sec. 18 T. 20S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 36-201-26 (Parcel No.) Charlston Park Ranchos (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	7	7
Calichie		7	9	2
Clay		9	27	18
Calichie		27	29	2
Clay		29	42	13
Calichie		42	44	2
Clay		44	54	10
Calichie	WB	54	56	2
Clay		56	67	11
Calichie	WB	67	69	2
Clay		69	78	9
Calichie	WB	78	80	2
Clay		80	94	14
Calichie	WB	94	96	2
Clay		96	118	22
Calichie	WB	118	120	2
Clay		120	129	9
Calichie	WB	129	131	2
Clay		131	140	9

RECEIVED
MAR 16 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 2-1, 1993
Date completed 2-5, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12¼	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation 1/8 x 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 49 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Great Basin Drilling
Address (Contractor) HCR 78 Box 80358
Pahrump NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
(By driller performing actual drilling on site or contractor)
Date 3-9-93

(Rev. 3-91)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627