WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40720
Permit No.
Basin

NOTICE OF INTENT NO. 23705

1. OWNER Cal Nev Pipeline Co.
MAILING ADDRESS C/o Converse Consultants 4670 S. Polaris Ave. L.V.
ADDRESS AT WELL LOCATION Cal Nev 5049 N. Sloan Lane Las Vegas, NV.
2. LOCATION SW ¼ NW ¼ Sec. 34 T. 19 N(S) R. 60 E. Clark County
PERMIT NO. Mo-7258 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Very fine Sand		0	10	10
gravel w/ Sand		10	20	10
" /Sand / Silt		20	40	20
Sandy clay		40	70	30
Silty clay w/ gravel		70	75	5.
Clay w/ silt		75	127	52.

T.D = 127

RECEIVED
MAR 26 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 3-15, 1993
Date completed 3-15, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 127 Feet Depth Cased 127 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches	0 Feet	127 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	.71 lbs	Sch. 40	0	127

Perforations:
Type perforation factory slotted
Size perforation 0.020
From 125 feet to 127 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-121 / 121-123 Bent.
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout w/ Bent.
Gravel Packed: ☑ Yes ☐ No
From 123 feet to 127 feet

9. WATER LEVEL
Static water level 100' Approx. feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Richard LeBlanc Contractor
Address 4670 S. Polaris Ave. Contractor
Las Vegas NV. 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1817
Signed R. LeBlanc By driller performing actual drilling on site or contractor
Date 3-25-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627