

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23701

1. OWNER Fitzgerald Property ADDRESS AT WELL LOCATION _____
MAILING ADDRESS C/o Condense Consultants 150' N. of Stewart in alley
4670 S. Polaris Ave, Las Vegas, NV between 10th & 11th ST. L.V.
2. LOCATION SE 1/4 NE 1/4 Sec 34 T. 26 N. R. 61 E Clark County
PERMIT NO. Mo. 2260 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
ASPHALT		0	.5	.5
Fill		.5	2.0	1.5
Clayey silt w/ sand		2	7	5
Sand w/ silt		7	12	5
Silty clay w/ gravel		12	14.5	2.5
Silty sand		14.5	18	3.5
Sand w/ silt		18	23	5
Silty clay w/ sand		23	25	2

T.D. = 25'

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet
HOLE DIAMETER (BIT SIZE)
From _____ To _____
8 Inches _____ Feet 25 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>.7165</u>	<u>SCH. 40</u>	<u>0</u>	<u>25</u>

Perforations:
Type perforation factory slotted
Size perforation 0.020
From 10 feet to 25 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 0-7/5-7 Bent. Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 7 feet to 25 feet

RECEIVED

MAR 26 1993

Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 3-23, 1993
Date completed 3-23, 1993

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
Static water level _____ feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Richard LeBlanc Contractor
Address 4670 S. Polaris Ave.
Las Vegas NV. 89103
Nevada contractor's license number issued by the State Contractor's Board _____
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1817
Signed R. LeBlanc
By driller performing actual drilling on site or contractor
Date 3-25-93