WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40727
Permit No.
Basin 212

NOTICE OF INTENT NO. 11378

1. OWNER Clark Co School Dist.
MAILING ADDRESS c/o Converse Consultants 4670 S. Polaris Ave, L.V.
ADDRESS AT WELL LOCATION Clark Co. School S.W. Corner of 25th St & Stewart Las Vegas, Nevada.

2. LOCATION NE ¼ SW ¼ Sec 36 T 20 N/S R 61 E Clark County
PERMIT NO. Mo. 2242 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	.5	.5
Fill - Type II		.5	2.5	2
Sand w/silt		2.5	4.5	2
Silty clay w/sand		4.5	9	4.5
Clay w/silt		9	16	7
clayey silt w/sand		16	22	6
Silt w/sand		22	30	8.
TD = 30'				

RECEIVED
MAR 26 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started Feb - 4, 1993
Date completed Feb 4, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 29' Feet Depth Cased 29' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	29' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	21bs	SCH. 40	0	29'

Perforations:
Type perforation factory slotted
Size perforation 0.020
From 4 feet to 29 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0.3 / 1-3 Bent.
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 3 feet to 29' feet

9. WATER LEVEL
Static water level Approx. 10' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RICHARD LeBLANC
Address 4670 S. Polaris Ave. Las Vegas NV. 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1817
Signed R. LeBlanc
By driller performing actual drilling on site or contractor
Date 3-26-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627