WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40728
Permit No.
Basin 212

NOTICE OF INTENT NO. 11941

1. OWNER Clark Co. School Dist.
MAILING ADDRESS c/o Converse Consultants 4670 S. Polaris Ave, Las Vegas
ADDRESS AT WELL LOCATION Clark Co. School S.W. Corner of 25th St & Stewart. Las Vegas, Nevada.

2. LOCATION NE ¼ SW ¼ Sec. 36 T. 20 N/S R. 61 E. Clark County
PERMIT NO. MO-2242 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt.		0	.5	.5
fill - Type II		.5	2	1.5
Clayey silt w/sand		2	4	2
Silty Sand		4	12	8
Silty Sand w/clay		12	15	3
Clayey silt w/sand		15	21	6
Silty Sand w/clay		21	24	3
Silty clay		24	30	6
T.D = 30'				

RECEIVED
MAR 26 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started Feb. 5, 1993
Date completed Feb. 5, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	30 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	21bs	Sch. 40	0	30

Perforations:
Type perforation Factory slotted
Size perforation 0.020
From 5 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-4 / 2-4 Bent.
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 4 feet to 30' feet

9. WATER LEVEL
Static water level Approx. 10' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Richard LeBlanc (Contractor)
Address 4670 S. Polaris Ave. (Contractor)
Las Vegas NV. 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1817
Signed R. LeBlanc (By driller performing actual drilling on site or contractor)
Date 3-26-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627