WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40741
Permit No.
Basin 212

NOTICE OF INTENT NO. 23721

1. OWNER: ARCO AM-PM
MAILING ADDRESS: C/O Broadbent & Assoc. 833 Nevada Hwy, BC NV.
ADDRESS AT WELL LOCATION: ARCO AM-PM 2728 LAS VEGAS BLVD S. LAS VEGAS, NV.

2. LOCATION: NW ¼ SE ¼ Sec. 9 T. 21 N/S R. 61 E. CLARK County

PERMIT NO. MO-2253 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED: ☑ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE: ☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ☐ Rotary ☐ RVC ☐ Air ☑ Other: Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0	.5	.5
Fill - Type II		.5	3	2.5
Sand		3	5	2
Clayey silt w/gravel		5	15	10
Cemented silt		15	18	3
Silt w/gravel		18	20	2.

J.D = 20'

RECEIVED
MAR 26 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 3-8 1993
Date completed 3-8 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches	0 Feet	20 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	.71 lbs	Sch. 40	0	20

Perforations:
Type perforation: factory slotted
Size perforation: 0.020
From 5 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0.4 / 2.4 Bent.
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 4 feet to 20 feet

9. WATER LEVEL
Static water level 11.26 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name: RICHARD LeBlanc (Contractor)
Address: 4670 S. Polaris Ave. Las Vegas Nevada (Contractor)
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1817
Signed: R. LeBlanc (By driller performing actual drilling on site or contractor)
Date: 3-26-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627