WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40742
Permit No.
Basin 212

NOTICE OF INTENT NO. 23726

1. OWNER TERRIBLE HERBST
MAILING ADDRESS C/O ~~Conners Co~~ Broadbent
833 Nevada Hwy, B.C. Nev.
ADDRESS AT WELL LOCATION TERRIBLE HERBST
N.E. Corner of Flamingo & Maryland
Las Vegas, NV.

2. LOCATION SW ¼ SW ¼ Sec. 14 T. 21 N/S R. 61 E. Clark County

PERMIT NO. MO 2261 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	.5	.5
Fill - Type II		.5	1	.5
clayey silt w/sand		1	1.5	.5
Caliche		1.5	2.	.5
Sandy silt w/ gravel & clay		2	7	5.
gravel		7	8	1
Sandy gravel w/silt.		8	14	6
gravel		14	18	4
Silty clay w/gravel		18	20	2
gravel		20	21	1
Silty clay		21	30	9.

I.D = 30'

RECEIVED
MAR 26 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 3-17, 1993
Date completed 3-17, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	30 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	2 lbs	Sch. 40	0	30

Perforations:
Type perforation factory slotted
Size perforation 0.020
From 5 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0.4/2.4 Bent.
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 4 feet to 30 feet

9. WATER LEVEL
Static water level Approx. 10' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of ~~my knowledge~~.
Name Richard LeBlanc (Contractor)
Address 4670 S. Polaris Ave. (Contractor)
Las Vegas, NV. 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on site driller M1817
Signed R. LeBlanc
By driller performing actual drilling on site or contractor
Date 3.26.93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627