WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40763
Permit No.
Basin 716

NOTICE OF INTENT NO. 22305

1. OWNER Glen Gibson
MAILING ADDRESS 965 Truckee Lane Fernley NV. 89403
ADDRESS AT WELL LOCATION 965 Truckee Lane, Fernley NV.

2. LOCATION NE ¼ NE ¼ Sec. 15 T. 20 N/S R. 24 E. Lyon County
PERMIT NO. NA (Issued by Water Resources) 20-261-0 (Parcel No.) Western Rancho (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Top Soil.		0	14'	14'
Boulders And Gravel - Sand		14'	44'	30'
Course Sand And Silt		44'	54'	10
Brown Clay With Some Gravel		54'	95'	41
Boulders & Gravel		95	118	23'
Tan, Broken Sand Stone,		118	125	7'

STATE ENGINEERS OFFICE RECEIVED 93 MAR 22 A11:27

Date started 2/16, 1993
Date completed 2/19, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air developed for 3 hrs at 30 GPM From 125 feet.		

8. WELL CONSTRUCTION
Depth Drilled 125 Feet Depth Cased 125 Feet

HOLE DIAMETER (BIT SIZE)
11" Inches From 0 Feet To 125 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	188	+1	125'

Perforations:
Type perforation 1/8 x 1" - 1" inch apart
Size perforation
From 95' feet to 125' feet
From feet to feet
From feet to feet
From 5# Rows feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 125' feet

9. WATER LEVEL
Static water level 42 feet below land surface
Artesian flow NA G.P.M. 30 P.S.I.
Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address PO. Box 599 (Contractor)
Silver Springs NV. 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 3/18/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627