WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40769
Permit No.
Basin 76

NOTICE OF INTENT NO. 23006

1. OWNER Glen Gibson
MAILING ADDRESS 965 TRUCKEE LANE
FERNLEY NV. 89403
ADDRESS AT WELL LOCATION 965 TRUCKEE LANE.
FERNLEY NEVADA, 89403

2. LOCATION NE ¼ NE ¼ Sec. 15 T. 20 N/S R. 24 E. LYON County
PERMIT NO. NA (Issued by Water Resources) 20-261-0 (Parcel No.) WESTERN RANCHO (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Well Went Dry. We Cleaned Hole out to 58' feet after Trying to pull Casing. We then Used our Air Star Preforator to Put 6 Rows of Preforations 1/8x1" One inch apart from 30' to 58' feet then we Ran Tremmey pipe to Bottom and pressure Grouted entire Hole Back to Surface with Neat Cement.				

Date started 2/22, 19 93
Date completed 2/23, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NA		

8. WELL CONSTRUCTION
Depth Drilled 58' Feet Depth Cased 58' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Not Known Inches		Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	188	+1	58'

Perforations:
Type perforation
Size perforation
From 30' feet to 58' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal NOT KNOWN
Placement Method: ☒ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ? feet to ? feet

9. WATER LEVEL
Static water level NA feet below land surface
Artesian flow NA G.P.M. — P.S.I.
Water temperature — °F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address P.O. Box 599 (Contractor)
Silver Springs NV. 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed Mathew L. Leach (By driller performing actual drilling on site or contractor)
Date 3/18/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

'93 MAR 22 A11 :28

RECEIVED
STATE ENGINEERS OFFICE