

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20562

1. OWNER BRADY BITZ ADDRESS AT WELL LOCATION 2950 Antelope Valley Rd.  
MAILING ADDRESS 3965 Bria Cir. Reno, NV 89506  
Sparks, NV 89436

2. LOCATION NW 1/4 NEW 1/4 Sec. 14 21 T. 22N N/S R. 1920 E Washoe County  
PERMIT NO. 079-480-3942 Antelope Valley Red Rock E.L. #237  
Issued by Water Resources Parcel No. Subdivision Name Red. 4

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay with decomposed granite mixed		1	11	10
Weathered granite		11	28	17
Green weathered granite		28	59	31
Brown rusty granite		59	71	12
Gray hard granite		71	148	77
Fracture	X	148	159	11
Gray granite		159	180	21
Fracture	X	180	186	6
Gray granite		186	200	14

8. WELL CONSTRUCTION  
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

From	To
10 Inches	50 Feet
8 5/8 Inches	200 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	200

Perforations:  
Type perforation factory sawed slot  
Size perforation 3/32 x 3 x 5 around

From 150 feet to 170 feet  
From 175 feet to 195 feet

Surface Seal:  Yes  No Seal Type: \_\_\_\_\_  
Depth of Seal 50 \_\_\_\_\_  
Placement Method:  Pumped  Poured  
 Neat Cement  Cement Grout  Concrete Grout

Gravel Packed:  Yes  No  
From 50 feet to 200 feet

9. WATER LEVEL  
Static water level 100 feet below land surface  
Artesian flow 40 G.P.M. P.S.I.  
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Wayne Drilling, Inc. Contractor  
Address P.O. Box 12370 Contractor  
Reno, NV 89510 Contractor  
Nevada contractor's license number 22549 issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
Signed Wayne C. Feldman  
By driller performing actual drilling on site or contractor  
Date March 29, 1993

Date started 3-22-93, 19\_\_\_\_  
Date completed 3-24-93, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)