

Log No. 40712
Permit No. 85
Basin 85

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21802

1. OWNER Murray Nadell ADDRESS AT WELL LOCATION 750 Quintero Ln Sparks, NV 89441
MAILING ADDRESS 16201 Hartsook St Encino, Ca 91436 Lot 52 Parcel A of Map 1694

2. LOCATION SW 1/4 NW 1/4 Sec 18 T 21 N/S R 21 E Washoe County County
PERMIT NO. 076-360-52 - Spanish Springs Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
D.G.		0	270	270
Mix clay and D.G.		270	278	8
D.G. firm		278	288	10
D.G. Hard		288	295	7
D.G. Firm hard		295	365	70
Granite hard & D.G.		365	597	232
T.D. 597 ft				
1993 MAR 26 10:00 AM STATE ENGINEERS OFFICE				
deepened by well log # <u>113066</u>				
<u>39.690440°N NAD27</u>				
<u>119.674650°W</u>				

8. WELL CONSTRUCTION
Depth Drilled 597 Feet Depth Cased 597 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>10 5/8</u>	<u>0</u>	<u>50</u>
<u>8 1/2</u>	<u>50</u>	<u>597</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+ 1</u>	<u>597</u>

Perforations:
Type perforation factory
Size perforation 3/32 X 3
From 559 feet to 579 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50+ Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 597 feet

9. WATER LEVEL
Static water level 520 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc
Address 625 Spice Islands Dr Suite L Sparks, Nv 89431

Nevada contractor's license number 15291
issued by the State Contractor's Board
Nevada driller's license number issued by the 1804
Division of Water Resources, the/on-site driller

Signed Roger M Thrall
By driller performing actual drilling on site or contractor
Date Roger M Thrall - President 3/8/93

Date started 2/25/93 19____
Date completed 3/4/93 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		<u>1 1/2</u>