WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40786
Permit No.
Basin 92B

NOTICE OF INTENT NO. 21632

1. OWNER PAUL ROMERO
MAILING ADDRESS 2500 Valley Road, #20
Reno, NV 89512

ADDRESS AT WELL LOCATION 11555 Sitka
Reno, NV 89506

2. LOCATION SE ¼ NW ¼ Sec. 22 T. 21N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 080-303-01 (Parcel No.) Lemmon Valley (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	9	8
Fine broan sand		9	11	2
Brown clay		11	38	27
Brown sandy clay		38	81	43
Soft zone-Fine sand		81	84	3
Brown sandy clay		84	106	22
Soft zone-Fine sand		106	111	5
Brown clay		111	119	8
Soft zone-coarse sand & gravels	X	119	133	14
BRown clay		133	137	4
Brown sand with clay streaks		137	148	11

Date started 3-25-93, 19
Date completed 3-26-93, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 148 Feet Depth Cased 148 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	148 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	148

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 122 feet to 142 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 148 feet

9. WATER LEVEL
Static water level 72 feet below land surface
Artesian flow 20 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed Gary C. Hedman (By driller performing actual drilling on site or contractor)
Date March 29, 1993

APR 1 '93 STATE ENGINEER

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627