WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40798
Permit No.
Basin 102

NOTICE OF INTENT NO. 23982

1. OWNER Doug Kasulka
MAILING ADDRESS P.O. Box 1178
Dayton, Nv. 89403

ADDRESS AT WELL LOCATION 3285 5th St.
Silver Springs Nv. 89429

2. LOCATION NW ¼ NW ¼ Sec. 16 T. 17 N/S R. 25 E. Lyon County
PERMIT NO. — (Issued by Water Resources) 17-351-05 (Parcel No.) Lahontan Sub #2 (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine Brown Sand		0	3	3
Hard Brown clay		3	6	3
Fine To corse Brown sand		6	45	39
Gray & some Gray Sand		45	60	15
Gray Fine To corse sand		60	105	45
Brown Fine To corse sand + some Brown clay	X	105	135	30
Brown clay		135	140	5
Gray clay + sand	X	140	145	5
Brown corse sand	X	145	160	15
Gray Sand + clay		160	165	5
Brown Fine To corse Sand	X	165	198	33
Gray clay + Sand		198	200	2

'93 MAR 30 A10:59 STATE ENGINEER'S OFFICE

Date started 3-24, 1993
Date completed 3-26, 1993

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18	3	4

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	200 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝		.188	0	200

Perforations:
Type perforation Mill
Size perforation 3 X 3/32
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 32 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ace Drilling + Development (Contractor)
Address P.O. Box 668 (Contractor)
Silver Springs, Nv. 89429
Nevada contractor's license number issued by the State Contractor's Board 14299
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 726
Signed H. L. [illegible] (By driller performing actual drilling on site or contractor)
Date 3-27-1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627