WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40800
Permit No.
Basin 103

NOTICE OF INTENT NO. 224,90

1. OWNER Allen Six
MAILING ADDRESS 5700 Goni
Carson City 89706

ADDRESS AT WELL LOCATION 174 Mary Street 89403

2. LOCATION NW ¼ SW ¼ Sec. 20 T. 17 N/S R. 22 E. Storey County
PERMIT NO. N/A (Issued by Water Resources) Lt 32 Unit 7 (Parcel No.) Mark Twain (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
dirt large boulders		0	117	117
gravel		117		
broken shell		117	221	104
some clay mixtures		221	276	55
Hard fractured				
black shell	✓	264		
Thin clay layer	✓	276	279	3
broken black shell	✓	279	320	41'
some chrystal mix				

RECEIVED MAR 22 '93 A11:28 STATE ENGINEERS OFFICE

Date started 3/6, 1993
Date completed 3/15, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30 gpm	from 320'	

8. WELL CONSTRUCTION
Depth Drilled 0 Feet Depth Cased 321 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	60 Feet
8 3/4 Inches		60 Feet	320 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	1.88	0	320

Perforations:
Type perforation Gun Start Perforator
Size perforation 1/8 x 1 x (-) 1" apart x 5 rows
From 260 feet to 320 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 320 feet

9. WATER LEVEL
Static water level 237' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F. Quality Clear, Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling (Contractor)
Address P.O. 599 Silver Springs (Contractor)
NV, 89426
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740-T1
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 3/15/93

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 1-90) (O)-627