

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22426

1. OWNER Ralph Parish ADDRESS AT WELL LOCATION 568 Lee Pkwy Gardnerville NV
 MAILING ADDRESS 1 P.P. 1412 Gardnerville NV
 2. LOCATION SW 1/4 SW 1/4 Sec. 25 T. 12 N/S R. 19 E Douglas County
 PERMIT NO. 19-410-124 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVG
 Air Other M.V.O.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand & Granite boulders		0	60	60
Brown sandy clay gravels		60	65	5
Small amount of water course D.C. sands		65	75	10
Granite Boulder & sand		90	115	25
		115	130	15

8. WELL CONSTRUCTION
 Depth Drilled 130 Feet Depth Cased 130 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 130 Feet
1 1/4 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.23</u>	<u>.188</u>	<u>0</u>	<u>130</u>

Perforations:
 Type perforation Mill slot
 Size perforation 3 x 3/32
 From _____ feet to _____ feet
 From 105 feet to 130 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 55 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 55 feet to 130 feet

9. WATER LEVEL
 Static water level 45 feet below land surface
 Artesian flow _____ G.P.M. 397 P.S.I.
 Water temperature Cold °F Quality Good

Date started _____ 19 93
 Date completed _____ 19 93

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	
G.P.M.	Draw Down (Feet Below Static)		
<u>30</u>	<u>21</u>		<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name _____
 Address A & H RUMR CO.
5551 Hwy. 50 East #C
Carson City, Nevada 89301
883-0459 - 883-1100
 Nevada contractor's license number 31839
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
 Signed Joel Smith
 By driller performing actual drilling on site or contractor
 Date _____

93 MAR 24 P302
 REGISTERED STATE ENGINEERS OF NV

