

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22279

1. OWNER MRS MRS DAVID SPAULDING ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS GARDNERVILLE 1443 RABBIT BRUSH  
GARDNERVILLE  
 2. LOCATION SW 1/4 SE 1/4 Sec. 36 T. 13 N. R. 20 E DOUGLAS County  
 PERMIT NO. \_\_\_\_\_ 23-472-50 WILDFLOWER Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY		0	25	25
GRAVEL w/CLAY		25	72	47
CLAY		72	78	6
GRAVEL w/CLAY		78	95	17
CLAY		95	247	152
GRAY CLAY		247	282	35
SANDY CLAY		282	306	24
GRAY CLAY		306	362	56
SANDY CLAY		362	398	36
GRAY CLAY		398	466	68
SANDY CLAY		466	482	16
GRAY CLAY		482	539	57
SANDY CLAY		539	545	6
GRAY CLAY		545	551	6
COARSE SAND w/CLAY	✓	551	555	4
GRAY CLAY		555	569	14
COARSE SAND w/CLAY	✓	569	578	9
GRAY CLAY		578	582	4
COARSE SAND	✓	582	614	32
GRAY CLAY		614	615	1

MAR 22 AM 124  
STATE ENGINEERING CO.

8. WELL CONSTRUCTION  
 Depth Drilled 615 Feet Depth Cased 615 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet  
5 5/8 Inches 580 Feet 615 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>580</u>
<u>5</u>	<u>8</u>	<u>.188</u>	<u>575</u>	<u>615</u>

Perforations:  
 Type perforation FACTORY SLOTTED  
 Size perforation 3 x 3/32  
 From 540 feet to 580 feet  
 From 575 feet to 615 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 580 feet

9. WATER LEVEL  
 Static water level 220 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature WARM °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDCO EXPLORATION, INC. Contractor  
 Address 7780 CURRY RD. Contractor  
FALLON, NV  
 Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726  
 Signed Pat J. Moore  
 By driller performing actual drilling on site of Contractor  
 Date 3/9/93

Date started 93 2/22, 1993  
 Date completed 3/9, 1993

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>10+</u>	<u>—</u>	<u>6</u>