WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40805
Permit No.
Basin 105

NOTICE OF INTENT NO. 23526

1. OWNER RICK DECARLO CONST.
MAILING ADDRESS GARDNERVILLE
ADDRESS AT WELL LOCATION 2809 WADE GARDNERVILLE

2. LOCATION SW ¼ SE ¼ Sec. 27 T. 14 (N)/S R. 20 E. DOUGLAS County
PERMIT NO. — (Issued by Water Resources) | Parcel No. 21-152-11 | Subdivision Name JOHNSON LANE

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| SAND | | 0 | 8 | 8 |
| SAND W/CLAY | | 8 | 136 | 128 |
| SANDY CLAY W/GRAVEL | ✓ | 136 | 178 | 42 |
| SAND + GRAVEL | ✓ | 178 | 190 | 12 |

'93 MAR 22 A11:24
STATE ENGINEER

Date started 3/10, 1993
Date completed 3/15, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| AIR | 10+ | — | 2 |

8. WELL CONSTRUCTION
Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From (Feet) | To (Feet) |
|---|---|---|
| 10 5/8 | 0 | 190 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12 | .188 | 0 | 190 |
| | | | | |

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 3 x 3/32
From 170 feet to 190 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 190 feet

9. WATER LEVEL
Static water level 85 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC. (Contractor)
Address 7780 CURRY RD. (Contractor)
FALLON, NV
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
Signed Patt J. Moore (By driller performing actual drilling on site or contractor)
Date 3/15/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627