

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22277

1. OWNER JERRY PALMER ADDRESS AT WELL LOCATION 2777 ESAW  
 MAILING ADDRESS 2777 ESAW GARDNERVILLE GARDNERVILLE  
 2. LOCATION NE 1/4 SW 1/4 Sec. 35 T. 14 N. R. 20 E. DOUGLAS County  
 PERMIT NO. 21-250-41 JOHNSON LANE Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	8	8
SANDY CLAY		8	62	54
CLAY		62	81	19
SANDY CLAY		81	147	66
CLAY		147	176	29
SANDY CLAY		176	219	43
CLAY		219	237	18
SANDY CLAY		237	275	38
DG W/CLAY		275	328	53
FRACTURED GRANITE	✓	328	359	31
GRANITE		359	365	6

'93 MAR 22 AM 11:24  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 365 Feet Depth Cased 365 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 365 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>365</u>

Perforations:  
 Type perforation FACTORY SLOTTED  
 Size perforation 3 x 3/32  
 From 325 feet to 365 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 365 feet

9. WATER LEVEL  
 Static water level 165 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality GOOD

Date started 1/22 1993  
 Date completed 2/3 1993

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>8</u>	<u>—</u>	<u>8</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDCO EXPLORATION, INC Contractor  
 Address 7780 CURRY RD. Contractor  
FALLON, NV  
 Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726  
 Signed Pat J. Moore  
 By driller performing actual drilling on-site or contractor  
 Date 2/3/93