WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40808
Permit No.
Basin 107

NOTICE OF INTENT NO. 22425

1. OWNER Robert & Susan L. Lumberry ADDRESS AT WELL LOCATION 81 Lower Colony Rd. Smith Valley NV.
MAILING ADDRESS 81 Lower Colony Rd. Smith Valley NV.

2. LOCATION SE ¼ NW ¼ Sec. 34 T. 11 N/S R. 23 E. Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. 10-351-16 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Hard Pack Sand		3	15	12
3/8 Gravels		15	25	10
Brown Sandy Clay		25	30	5
Brown Clay w/ 3/8 Gravels		30	45	15
Soft Sand		45	80	35
1/4 to 3/8 Gravels Some Water	X	85	105	20
Brown Sandy Clay		105	130	25
3/8 Gravels Water	XXX	130	140	10
Brown Gummy Clay		140	145	5
3/8 - 1/4 Gravels		145	155	5

Date started 3/12, 1993
Date completed 3/15, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50-75	10'	2½

8. WELL CONSTRUCTION
Depth Drilled 155 Feet Depth Cased 155' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11½ Inches	0 Feet	155' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188		

Perforations:
Type perforation Mill Slot
Size perforation 3½ X 3/32
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100' feet to 155' feet

9. WATER LEVEL
Static water level 80' feet below land surface
Artesian flow G.P.M. 25 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP CO. Contractor
Address 5551 Hwy. 50 East Carson City, Nevada 89 Contractor
883-0459 885-1
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joe Butt
By driller performing actual drilling on site or contractor
Date 3-15-93

MAR 19 '93 P.2.5
STATE ENGINEER

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627