WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40809
Permit No.
Basin 137A

NOTICE OF INTENT NO. 21761

1. OWNER Bryan Amato
MAILING ADDRESS P.O. Box # 3269
Tonopah, NV 89049

ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ NE ¼ Sec. 13 T. 6 ~~N~~ S R. 40 E ~~20-100-40.71~~ NYE County
PERMIT NO. 31053 & 31054 (Issued by Water Resources) 20-100-40.71 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	8	8
Lightly Cemented S&G		8	43	35
Sandy Clay		43	54	11
Cemented Sand & Grav.		54	66	12
Sand		66	70	4
Cemented Sand & Grav.		72	74	2
Sand & Clay		74	81	7
Cemented Sand & Grav.		81	87	6
Sandy Clay		87	94	7
Sand & Gravel		94	110	16
Sand Stone	x	110	124	14
Clay		124	132	8
Sand Stone		132	143	11
Sand & Gravel	x	143	156	13
Clay		156	159	3
Cemented Sand & Gra.		159	165	6
Clay		165	167	2
Cemented Sand & Grav		167	175	8
Gravel	x	175	178	3
Cemented Sand & Grav.		178	183	5
Gravel & Sand	x	183	185	2
Sand Stone		185	191	6
Sand, Gravel, Clay		191	195	4
Clay		195	200	5

Date started January 15, 19 93
Date completed March 15, 19 93

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	0	2 HR

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 201 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	50 Feet
10 Inches		50 Feet	110 Feet
8 Inches		110 Feet	200 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.625	16.90	.188	+1½	201

Perforations:
Type perforation machine cut
Size perforation ⅛" x 2"
From 100' feet to 190' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 50 feet to 100 feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DeLon Winsor (Contractor)
Address PO Box # 116 (Contractor)
Silver Peak, NV 89047
Nevada contractor's license number issued by the State Contractor's Board 35005
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 783
Signed DeLon Winsor (By driller performing actual drilling on site or contractor)
Date 3-17-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627