

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 22316

1. OWNER Rock Springs Ranch/DBA R.O. RANCH ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 2050 No. physical address
King City, CA. 93930 CIRAC Valley
 2. LOCATION SE NW SE 1/4 Sec. 20 T. 7 N. R. 39 E. Nye County
 PERMIT NO. 56257-W378 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Rotary
 Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-------------------|--------------|------|-----|------------|
| fluv. | | 0 | 15 | 15 |
| SS w/mixed gravel | | 15 | 55 | 40 |
| Brn Clay | | 55 | 58 | 3 |
| Red Rock | | 58 | 76 | 18 |
| Red clay | | 76 | 85 | 9 |
| Red Rock | | 85 | 110 | 25 |
| white clay | | 110 | 120 | 10 |
| Red clay | | 120 | 145 | 25 |
| white clay | | 145 | 150 | 5 |
| orange clay | | 150 | 160 | 10 |
| SS | | 160 | 180 | 20 |
| TAN siltstone | | 180 | 210 | 30 |
| Basalt | (400) | 210 | 405 | 195 |

Fracture

93 MAR 29 P2 02 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Diameter 12 1/4 inches Total depth 405 feet
8 3/4 inches
 inches
 Casing record 6 3/8 + 1 - 405
 Weight per foot 13.92 Thickness 1204

| Diameter | From | To |
|-----------------|-----------------|-----------------|
| <u>6</u> inches | <u>+ 1</u> feet | <u>405</u> feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

 Surface seal: Yes No Type NEAT Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation milled
 Size perforation 1/8 x 3
 From 385 feet to 405 feet
 From _____ feet to _____ feet

Date started 3-15, 1993
 Date completed 3-22, 1993

9. WATER LEVEL
 Static water level 325 feet below land surface
 Flow 15-20 G.P.M. P.S.I.
 Water temperature 70 °F Quality good

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|-----------------|--------|-----------|------------------|
| <u>Air Lift</u> | | | |
| | | | |
| | | | |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Woytek Drilling Co Contractor
 Address 2220 Stone Dr. Reno NV. Contractor
 Nevada contractor's license number issued by the State Contractor's Board 024521
 Nevada contractor's driller's number issued by the Division of Water Resources 1374
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
 Signed Les Woytek
 By driller performing actual drilling on site or contractor
 Date 3-26-93

BAILER TEST N/A
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours