WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40823
Permit No.
Basin 76

NOTICE OF INTENT NO. 22493

1. OWNER Louie C Henderson
MAILING ADDRESS 875 Marget
Fenley NV. 89403

ADDRESS AT WELL LOCATION Same

2. LOCATION NE ¼ NE ¼ Sec. 15 T. 20 N/S R. 24 E. Lyon County

PERMIT NO. _____ Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand And Clay		0	10	10
Sand		10	17	7
Void		17	21	4
Course Sand Clay		21	36	15
Gravel And Sand		36	51	15
Sand And Clay		51	58	7
Clay		58	72	14
Course Sand Clay		72	85	13
Gravel with Cours Sand	✓	85	105	20

'93 APR 21 A10:26
RECEIVED
STATE ENGINEERS OFFICE

Date started 3/18/93, 19
Date completed 3/19/93, 19

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR Developed For 2 Hors			
produced 60 Gallen's A min.			

8. WELL CONSTRUCTION
Depth Drilled 105 Feet Depth Cased 105 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	[illegible] Feet	[illegible] Feet
Inches	0 Feet	105 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	3/16	0	105

Perforations:
Type perforation
Size perforation
From 80 feet to 105 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50 Feet
Placement Method: ☑ Pumped ☐ Poured

Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 105 feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow 60 G.P.M. P.S.I.
Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Leach Drilling Inc
Contractor
Address Po Box 599
Contractor
Silver Springs NV 89429

Nevada contractor's license number issued by the State Contractor's Board 0031841

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740-T-2

Signed [signature]
By driller performing actual drilling on site or contractor

Date 4/18/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627