WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40032
Permit No.
Basin 87

NOTICE OF INTENT NO. 20560

1. OWNER BRUCE McCUMBER
MAILING ADDRESS 1054 Cascade
Carson City, NV 89701

ADDRESS AT WELL LOCATION
22906 Carrage Dr.
Reno, NV 89511

2. LOCATION SE ¼ SE ¼ Sec 7 T 19N N/S R 20 E Washoe County
PERMIT NO. (Issued by Water Resources) 50-133-04 (Parcel No.) Pleasant VAlley (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Black sandy clay		0	10	10
Brown clay with boulders and gravels		10	46	36
Boulders Gravels and sand		46	83	37
Brown clay		83	89	6
Bolders gravels and sand		89	106	7
Soft zone - sand	X	106	118	12
Boulder, gravel, sand		118	128	10
Soft zone - gravel,sand	X	128	140	12
Boulder & gravel		140	150	10

'93 APR 19 P1:16
RECEIVED
STATE ENGINEERS OFFICE

Date started 4-6-93, 19
Date completed 4-9-93, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10	0	150

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	150

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 105 feet to 145 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 150 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow 20 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date April 14, 1993

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627