WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40835
Permit No.
Basin 89

NOTICE OF INTENT NO. 19756

1. OWNER Doug Bailey Const
MAILING ADDRESS 790 La Rue Ave. Reno Nv.
ADDRESS AT WELL LOCATION 27 Mulle St. New Washo City

2. LOCATION NW ¼ SW ¼ Sec. 32 T. 17 N/S R. 20 E. Washo County
PERMIT NO. (Issued by Water Resources) Parcel No. 050-398-07 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	10	10'
Course Sandstone		10	35	25'
Firm Brown Sandy Clay		35	60	25'
Hard Sandstone w/ Small Seams of Clay		60	110	50
Hard broken Granite		110	175	65
Brown White Clays		175	240	65
Hard Granite		240	265	25
Broken Granite		265	275	10

Date started 4-6, 1993
Date completed 4-8, 1993

7. WELL TEST DATA
TEST METHOD ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	25	2

8. WELL CONSTRUCTION
Depth Drilled 275' Feet Depth Cased 275' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 1/4 Inches	0 Feet	55 Feet
10 Inches	55' Feet	275 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	1.88	0	275'

Perforations:
Type perforation 3 1/2 X 3/32
Size perforation
From 255 feet to 275 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 275 feet

9. WATER LEVEL
Static water level 140' feet below land surface
Artesian flow G.P.M. 15 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name [redacted]
Address [redacted] Carson City, NV 89701 885-1889 Contractor's License 885-1889 Fax 882-5311
5551 Hwy 50 E. 17 M.I. Washo Co. C.C. NV.
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joe Butts
By driller performing actual drilling on site or contractor
Date 4/12/93

APR 16 P1:16 1993 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627