WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40837
Permit No.
Basin 91

NOTICE OF INTENT NO. 19699

1. ~~OWNER~~ Summit Engineering Corp.
MAILING ADDRESS 5405 Mae Anne Ave.
Reno, NV. 89523

Client:
ADDRESS AT WELL LOCATION Boomtown ~~Hotel~~ & Casino
Garson Rd & I-80
Verdi, NV

2. LOCATION SW ¼ NE ¼ Sec 16 T 19N N/S R 18 E Washoe County
PERMIT NO. M/O 504-A (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other Tubex

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Silty SAnd		0	4.5	4.5
Dk brown gravelly sand,		4.5	9	4.5
minor clay				
Gray med to fine grained		9	25	16
sand				
Gray gravelly sand		25	37	12
Black to gray sandy		37	48	11
boulder, gravel				
Dk gray sand		48	60	12
Dk gray gravelly sand		60	62	2
Dk gray sandy gravel		62	80	18

'93 APR 19 P1:18
STATE ENGINEER'S OFFICE

Date started August 4, 1992, 19
Date completed August 7, 1992, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NO TEST			

8. WELL CONSTRUCTION
Depth Drilled 80 Feet Depth Cased 79.5' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 5/16 Inches		0 Feet	80 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		Sch 40	0	79.5

Perforations:
Type perforation Slotted
Size perforation 0.020"
From 54 feet to 79.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50.5
Placement Method: ☐ Pumped ☒ Poured
Bentonite Seal @ 50.5-52.5'
Gravel Packed: ☒ Yes ☐ No
From 52.5 feet to 80 feet

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 65.3 feet below land surface
Artesian flow not known G.P.M. P.S.I.
Water temperature n/k °F Quality n/k

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed [signature] (By driller performing actual drilling on site or contractor)
Date April 12, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627