WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40839
Permit No.
Basin 10

NOTICE OF INTENT NO. 22607

1. OWNER Dennis Reid
MAILING ADDRESS 2610 Rice Road
Fallon, NV 89406

ADDRESS AT WELL LOCATION
4033 Cimarron Road
Fallon, NV 89406

2. LOCATION NE ¼ NE ¼ Sec 3 T 19 N/S X R 28 E Churchill County
PERMIT NO. (Issued by Water Resources) 008-691-88 (Parcel No.) Pheasant Green (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[XX] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	12	12
Brown CLay		12	18	6
Brown Coarse Sand		18	29	11
Brown Clay		29	35	6
Brown COarse Sand		35	43	8
Fine Gray Sand		43	46	3
Black & Green Coarse Sand		46	49	3
Black Sandy Clay		49	54	5
Fine GReen Sand		54	61	7
Black & Green Coarse Sand		61	69	8
Brown COarse Sand	X	69	83	14

'93 APR 16 P1:57
RECEIVED
STATE ENGINEER'S OFFICE

Date started April 6, 19 93
Date completed April 6, 19 93

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 83 Feet Depth Cased 83 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	83 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	83

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 78 feet to 82 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 65
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 65 feet to 83 feet

9. WATER LEVEL
Static water level 15' 8" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715

Signed Doug Parsons
By driller performing actual drilling on site or contractor
Date April 10, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627