WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40840
Permit No.
Basin 101
NOTICE OF INTENT NO.

1. OWNER Dividend Construction
MAILING ADDRESS P.O.BOX 1915
Fallon, NV 89407
ADDRESS AT WELL LOCATION 4130 Bottom Road
Fallon, NV 89406

2. LOCATION NE ¼ NE ¼ Sec. 33 T. 19 N/S R. 28 E. Churchill County
PERMIT NO. (Issued by Water Resources) 008-691-73 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	11	11
Brown Clay		11	19	8
Brown Coarse Sand		19	28	9
Fine Brown Sand		28	34	6
Brown Coarse Sand		34	43	9
Fine Green Sand		43	44	1
Black & Green Coarse Sand		44	50	6
Fine Gray Sand		50	54	4
Black & Green Coarse Sand		54	68	14
Brown Coarse Sand	X	68	86	18

'93 APR 16 P1:57
STATE ENGINEERS OFFICE

Date started April 5, 19 93
Date completed April 5, 19 93

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 86 Feet Depth Cased 86 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10	0	86

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	86

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 81 feet to 85 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 75
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 75 feet to 86 feet

9. WATER LEVEL
Static water level 16' 10" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715

Signed Doug Parson (By driller performing actual drilling on site or contractor)
Date April 10, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627