

OFFICE USE ONLY
 Log No. 40842
 Permit No. 101
 Basin I
 NOTICE OF INTENT NO. 2524

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

N19 E29 21 AABA 2

1. OWNER A & K Earthmovers ADDRESS AT WELL LOCATION Enterprise Way
 MAILING ADDRESS P.O. Box 1059 Fallon, NV 89406
Fallon, NV 89407
 2. LOCATION SE NE 1/4 NW 1/4 Sec 21 T 19 N X R 29 E Churchill County
 PERMIT NO. 57193 007-311-43 Subdivision Name _____
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand		0	33	33
Brown Clay		33	35	2
Black Clay		35	48	13
Black Sand		48	56	8
Black Clay		56	70	14
Black & Green Coarse Sand		70	74	4
Black Clay		74	78	4
Black & Green Sand		78	81	3
Brown Sandy Clay		81	86	5
Brown Coarse Sand		86	95	9
Brown Clay Sandy		95	110	15
Brown Coarse Sand		110	116	6
Brown Clay		116	119	3
Brown Coarse Sand		119	121	2
Brow Clay		121	138	17
Green Clay		138	158	20
Black Clay		158	166	8
Black & Green Coarse Sand		166	173	7
Fine Gray Sand		173	181	8
Black Clay		181	186	5
Fine Gray Sand		186	195	9
Black & Green Coarse Sand		195	207	12
Green Clay		207	219	12
Brown Clay		219	222	3
Green Clay		222	226	4
Green & White Coarse Sand		226	241	15

8. 307 WELL CONSTRUCTION
 Depth Drilled 12 Feet Depth Cased 12-307 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet 307 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 7/8	16.94	.188	0	307

Perforations:
 Type perforation Mill Cut
 Size perforation 277 feet to 307 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 307 feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Parsons Drilling, Inc. Contractor
 Address P.O. Box 1265 Contractor
Fallon, NV 89407-1265
 Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
 Signed Doug Pearson
 By driller performing actual drilling on site or contractor
 Date April 9, 1993

Sand March 22 1993
 Date started _____
 Date completed March 22 1993

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

AMENDED PER PHONE CALL
 W/ DRILLER 9-16-94

MAR 16 9 15 AM '93
 STATE ENGINEER'S OFFICE

