

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
 Log No. 40844  
 Permit No. 102  
 Basin 102

NOTICE OF INTENT NO. 19127

1. OWNER Rose Gage ADDRESS AT WELL LOCATION SAME  
 MAILING ADDRESS 3420 2nd St. Silver Springs NV 89429  
 2. LOCATION NE 1/4 NW 1/4 Sec 9 T. 17 @/S R. 25 E Lyon County  
 PERMIT NO. 112 Parcel No. Lake Side sub #2 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand	ND	0	4	4
Sand - Hard Clay	ND	4	10	6
Brown Clay	ND	10	15	5
Sand	NV	15	20	5
Brown Clay	ND	20	25	5
Sand	NV	25	50	25
Brown Clay + gravel	ND	50	55	5
Blue Clay	ND	55	60	5
Blue Clay + Black sand	yes	60	70	10
Brown Clay + Sand	yes	70	90	20
Brown Clay gravel	NV	90	100	10
Light Clay + Sand	yes	100	110	10

8. WELL CONSTRUCTION  
 Depth Drilled 110 Feet Depth Cased 110 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 60 Feet  
6 Inches 60 Feet 110 Feet  
 .....Inches.....Feet.....Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>188</u>	<u>0</u>	<u>110</u>

Perforations:  
 Type perforation Slotted  
 Size perforation 3/32  
 From 100 feet to 110 feet  
 From .....feet to .....feet  
 From .....feet to .....feet  
 From .....feet to .....feet  
 From .....feet to .....feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 60  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From .....feet to .....feet

9. WATER LEVEL  
 Static water level 60 feet below land surface  
 Artesian flow NO G.P.M. ..... P.S.I.  
 Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name S. A. Miller Contractor  
 Address P.O. 92 Wellington, NV 89444 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 32166  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1806  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 3/30/93

Date started 3 5, 1993  
 Date completed 3 30, 1993

7. WELL TEST DATA

TEST METHOD: <input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>15</u>	<u>15</u>	<u>1 hr.</u>	

APR 16 P1:58  
 RECEIVED  
 STATE ENGINEERS OFFICE