WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40845
Permit No.
Basin 102

NOTICE OF INTENT NO. 22499

1. OWNER Richard + Virginia Foster
MAILING ADDRESS 1630 Shiloh Court
ADDRESS AT WELL LOCATION 1960 Deen St
Silver Springs NV. 89429

2. LOCATION NE ¼ NE ¼ Sec. 30 T. 17 N/S R. 25 E. Lyon County
PERMIT NO. 17-44-301 (Issued by Water Resources) Parcel No. Riverside (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	40	40
Course Sand		40	52	12
Clay.		52	84	32
Clay And Sand and Gravels		84	130	46
Clay		130	145	15
Course Sand		145	162	17
Course Sand And Gravels	✓	162	200	38

RECEIVED STATE ENGINEERS OFFICE APR 21 '93 A10:27

Date started 4/1, 1993
Date completed 4/4, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air Developed For 8 Hours produced 80+ Gallens a min.		

8. WELL CONSTRUCTION
Depth Drilled 0-200 Feet Depth Cased 0-200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	3/16	+1	188

Perforations:
Type perforation AIR perforations
Size perforation
From 148 feet to 188 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50 Feet
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 188 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow 80+ G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address Po Box 599 (Contractor)
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1747-T-2
Signed Nathan Leach (By driller performing actual drilling on site or contractor)
Date 4/18/93

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (D)-627