

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22372

1. OWNER Ruby Morris ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1018 PONY CT 1018 PONY CT
GARDNERVILLE, NV 89410 GARDNERVILLE, NV 89410
 2. LOCATION NE 1/4 SW 1/4 Sec 17 T 12 N R 19 E DOUGLAS County
 PERMIT NO. APN2707019 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	3	
COBALES & GRAVELS		3	80	
SANDY BRN CLAY		80	83	
LG GRAVELS & SAND		83	100	
SANDY BRN CLAY		100	104	
LG GRAVELS & SAND		104	129	
SANDY BRN CLAY		129	131	
LG GRAVELS & SAND		131	140	

93 APR 13 AM 10:22
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
12 1/4 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>		<u>188'</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation FACTORY
 Size perforation 3/32 BY 3"
 From 120 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 140 feet

9. WATER LEVEL
 Static water level 7 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 3 29 1993
 Date completed 4 2 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>35+</u>		
	<u>35+</u>	<u>DDMT RUN 3 HR</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ED MILLER Contractor
 Address BOX 92
SMITH, NV 89444
 Nevada contractor's license number 32166
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1535
 Division of Water Resources, the on-site driller.
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 4/2/93