

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 40873  
 Permit No. \_\_\_\_\_  
 Basin 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 11958

1. OWNER REBEL oil ADDRESS AT WELL LOCATION REBEL oil  
 MAILING ADDRESS C/o Broadbent & Assoc. 3225 Las Vegas Blvd.,  
833 Nevada Hwy, B.C. Las Vegas, Nevada  
 2. LOCATION SE 1/4 SW 1/4 Sec 7 T 20 N R 62 E Clark County  
 PERMIT NO. Mo. 2250 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Sand</u>				
<u>Gravel w/silt &amp; clay</u>		<u>0</u>	<u>6</u>	<u>6</u>
<u>Sandy silt w/clay</u>		<u>6</u>	<u>12</u>	<u>12</u>
<u>Silty clay/some sand</u>		<u>12</u>	<u>15</u>	<u>3</u>
<u>Clayey silt/some sand</u>		<u>15</u>	<u>25</u>	<u>10</u>
<u>Gravel w/silt, sand &amp; clay</u>		<u>25</u>	<u>37</u>	<u>12</u>
<u>Caliche</u>		<u>37</u>	<u>38</u>	<u>1</u>
<u>Silty clay</u>		<u>38</u>	<u>70</u>	<u>32</u>

J.D = 70'

8. WELL CONSTRUCTION  
 Depth Drilled 70 Feet Depth Cased 70 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>	<u>21bs</u>	<u>SCH. 40</u>	<u>0</u>	<u>70</u>

Perforations:  
 Type perforation factory slotted  
 Size perforation 0.020  
 From 45 feet to 70 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 0.40 / 38.40 Bent.  Neat Cement  
 Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 40 feet to 70 feet

RECEIVED  
 APR 02 1993

9. WATER LEVEL  
 Static water level 40' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 3-18, 1993  
 Date completed 3-18, 1993

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name RICHARD UBLANC Contractor  
 Address 4670 S. TOLARIS AVE. Contractor  
Las Vegas NV. 89103  
 Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1817  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 3-29-93