WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40959
Permit No.
Basin 212

NOTICE OF INTENT NO. 10264

1. OWNER CITY OF HENDERSON
MAILING ADDRESS 240 WATER STREET
HENDERSON, NV. 89015

ADDRESS AT WELL LOCATION 2400 MOSER DRIVE
HENDERSON, NV 89015

2. LOCATION SW ¼ NE ¼ Sec. 31 T. 21 N/S R. 63 E. CLARK County
PERMIT NO. (Issued by Water Resources) Parcel No. WASTEWATER TREATMENT PLANT #3 (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GROUTED from total depth to surface. TREMMIED WITH NEAT CEMENT		0	25'	25'
EXISTING CASING AND SAND PACK drilled out and removed				

RECEIVED
APR 07 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started MARCH 1, 1993
Date completed MARCH 1, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	25 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	40	0.154	0	25

Perforations:
Type perforation factory slotted
Size perforation 0.020 inch
From 10 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 5 feet
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 9 feet to 25 feet

9. WATER LEVEL
Static water level 10.50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name TERRY SUMP (Contractor)
Address 1960 OBISPO #14 SIGNAL HILL CA. (Contractor)

Nevada contractor's license number issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1872-M

Signed (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627