

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 40980
 Permit No. 6-27
 Basin

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21214

1. OWNER Country Sleep Center ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 9200 S. Virginia
Reno NV

2. LOCATION NE 1/4 NE 1/4 Sec. 7 T. 18 N. R. 20 E. Washoe County
 PERMIT NO. m/o 480 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG m/1

Material	Water Strata	From	To	Thick-ness
The existing well was in good condition. It was pressure grouted from 15' to surface in one stage using 5 bags of portland type II cement with a 6 gallon per bag mixture; pushing well water to the surface.				
P&A log # 38057				

8. WELL CONSTRUCTION
 Depth Drilled 15 Feet Depth Cased 15 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches 0 Feet 15 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>		<u>Sch. 40</u>	<u>0</u>	<u>15</u>

Perforations:
 Type perforation factory slot
 Size perforation 100

From 5 feet to 15 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 3.5
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 3.5 feet to 15 feet

Date started 12/28 1992
 Date completed 12/29 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>NA</u>	<u>NA</u>	

9. WATER LEVEL
 Static water level 7 feet below land surface
 Artesian flow w/10 G.P.M. w/10 P.S.I.
 Water temperature 64.2 °F Quality w/10

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge

Name Andrew Drilling Contractor
 Address 1635 Bellard Rd Contractor
Reno NV, 89509

Nevada contractor's license number issued by the State Contractor's Board 34525
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028

Signed Andrew Drilling
 By driller performing actual drilling on site or contractor
 Date 3/1/93