WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70935
Permit No.
Basin 087

NOTICE OF INTENT NO. 21667

1. ~~OWNER~~ Consultant: Pezonella Associates, Inc.
MAILING ADDRESS 520 Edison Way
Reno, NV. 89502

Client:
ADDRESS AT WELL LOCATION Reson, Inc.
208 E. 4th St.
Reno, NV. 89502

2. LOCATION SE ¼ NE ¼ Sec. 11 T 19N N/S R 19 E Washoe County
PERMIT NO. M/O 619-A MW# 3
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [X] Other Tubex

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Concrete & Gravel Base		0	1	1
Brown Sandy Clay		1	11	10
Light Brown Silty Sand w/ Gravel		11	21	10
Gravel, Cobbles, & Boulders w/ Sand		21	39	18

Date started March 10, 1993, 19
Date completed March 11, 1993, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NO TEST			

8. WELL CONSTRUCTION
Depth Drilled 39 Feet Depth Cased 39 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 5/16 Inches	0 Feet	39 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4" PVC		SCH 40	0	39

Perforations:
Type perforation Factory Slotted
Size perforation 0.020"
From 9 feet to 39 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 6'
Placement Method: [ ] Pumped [X] Poured
Bentonite Seal @ 6'-8'
Gravel Packed: [X] Yes [ ] No
From 8 feet to 39 feet

Seal Type:
[ ] Neat Cement
[X] Cement Grout
[ ] Concrete Grout

9. WATER LEVEL
Static water level 26.65 feet below land surface
Artesian flow Not Known G.P.M. P.S.I.
Water temperature n/k °F Quality n/k

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. Contractor
Address P.O. BOX 12370 Contractor
RENO, NV. 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed [signature] By driller performing actual drilling on site or contractor
Date April 16, 1993

93 APR 29 AM 10:44
STATE ENGINEERS OFFICE

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627