WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40990
Permit No.
Basin 87

NOTICE OF INTENT NO. 21215

1. OWNER Virgil Wedge
MAILING ADDRESS 701 N. Sierra st
Reno NV
ADDRESS AT WELL LOCATION Same

2. LOCATION NE ¼ NW ¼ Sec. 11 T. 19 N/S R. 19 E. Washoe County
PERMIT NO. MW 6104 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☑ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG MW-3

Material	Water Strata	From	To	Thickness
Sandy clay - Brn		0	12'	12'
sand w/gravel - brn	40'	12	50'	38'

8. WELL CONSTRUCTION
Depth Drilled 50 Feet Depth Cased 50 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
5 Inches	0 Feet	50 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Sch. 40	0	50

Perforations:
Type perforation factory slot
Size perforation .020
From 35 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 30'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 30 feet to 50 feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow n/a G.P.M. n/a P.S.I.
Water temperature cold °F Quality n/a

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Anderson Drilling (Contractor)
Address 1635 Bellford Rd. (Contractor)
Reno NV 89509
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 3/1/93

Date started 12/22, 1992
Date completed 12/22, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

'93 MAY 12 A11:14
STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627