WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40792
Permit No.
Basin 087

NOTICE OF INTENT NO. 15409

1. ~~OWNER~~ Consultant: Harding Lawson Associates
MAILING ADDRESS 961 Matley Lane, Suite 110
Reno, NV. 89502

Client: All Right Corporation
ADDRESS AT WELL LOCATION 1st, 2nd, & Lake ST. Parking Area
Reno, NV.

2. LOCATION NE ¼ SE ¼ Sec. 11 T. 19N N/S R. 19 E. Washoe County
PERMIT NO. M/O 316 MW# 2 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [X] Other Tubex

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphaltic Concrete		0	3"	3"
DK Brown Silty Sand				
w/ Gravel				
Brown Silt w/ Sand		3"	9'	8'9"
Brown Poorly Graded		9	30	21
Gravel				

Date started October 15, 1990, 19
Date completed October 15, 1990, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NO TEST			

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
8 5/8	0	30

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" PVC		SCH 40	0	13
End Cap				
Locking Cap				

Perforations:
Type perforation Factory Slotted
Size perforation 0.020'
From 14 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 13'
Placement Method: [ ] Pumped [X] Poured
Bentonite sEal @ 11'-12'
Gravel Packed: [X] Yes [ ] No
From 13 feet to 30 feet

Seal Type:
[ ] Neat Cement
[X] Cement Grout
[ ] Concrete Grout

9. WATER LEVEL
Static water level NO STATIC
Artesian flow G
Water temperature °F Quality H2O LEVEL

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NV. 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed (By driller performing actual drilling on site or contractor)
Date April 16, 1993

'93 APR 29 A10:47 RECEIVED STATE ENGINEERS OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627