WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40993
Permit No.
Basin 087

NOTICE OF INTENT NO. 15409

Consultant:
1. ~~OWNER~~ Harding Lawson Associates
MAILING ADDRESS 961 Matley Suite 110
Reno, NV. 89502

Client:
ADDRESS AT WELL LOCATION All Right Corporation
1st, 2nd, and Lake St. Parking Area
Reno, NV.

2. LOCATION NE ¼ SE ¼ Sec. 11 T. 19N N/S R. 19 E. Washoe County
PERMIT NO. M/O 316 MW# 3 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [X] Other Tubex

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphaltic Concrete		0	4	4
brown silty sand w/ gravel				
Brown Clayey Sand w/ gravel		4	7	3
Brown silty sand w/ gravel		7	12	5
Gray Brown Poorly graded gravel w/ sand		12	25	13

'93 APR 29 A10:47
STATE ENGINEER'S OFFICE

Date started October 16, 1990, 19
Date completed October 16, 1990, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NO TEST			

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 5/8	Inches	0 Feet	25 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" PVC		SCH 40	0	7
End Cap				
Locking Cap				

Perforations:
Type perforation Factory Slotted
Size perforation 0.020"
From 8 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 7'
Placement Method: [ ] Pumped [X] Poured
Bentonite Seal @ 6'-7'
Gravel Packed: [X] Yes [ ] No
From 7 feet to 25 feet

Seal Type:
[ ] Neat Cement
[X] Cement Grout
[ ] Concrete Grout

9. WATER LEVEL
Static water level 20' feet below land surface
Artesian flow Not Known G.P.M. P.S.I.
Water temperature n/k °F Quality n/k

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NV. 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed [signature] (By driller performing actual drilling on site or contractor)
Date April 16, 1993

(Rev. 3-91)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627