WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41044
Permit No.
Basin 105

NOTICE OF INTENT NO. 22427

1. OWNER Greg Davies
MAILING ADDRESS 2119 Fish Springs Rd. Gardnerville NV.
ADDRESS AT WELL LOCATION 772 Saddle Ct. Gardnerville NV.

2. LOCATION NW ¼ NE ¼ Sec. 24 T. 12 N/S R. 21 E. Douglas County
PERMIT NO. ____ Issued by Water Resources | 29-462-56 Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	15	15
Gravels		15	35	20
Gumbo Brown Clay		35	60	25
Broken hard volcanic Rock		60	130	70
Gravels w/Small Amount of Water		130	135	5
Broken Volcanic Rock		135	160	25
Gravels w/Small Clay Seams		160	185	25
Good Gravels Water Zone	xxx	185	200	15

Date started 4-16, 1993
Date completed 4-19, 1993

'93 MAY 10 A9:51
RECEIVED
STATE ENGINEERS OFFICE

7. WELL TEST DATA
TEST METHOD ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	20	2½

8. WELL CONSTRUCTION
Depth Drilled 200' Feet Depth Cased 200' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11¼" Inches	0 Feet	55' Feet
10" Inches	55' Feet	200' Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	200'

Perforations:
Type perforation Mill shot
Size perforation 3½ x 3/32
From ____ feet to ____ feet
From 180 feet to 200' feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55' feet to 200' feet

9. WATER LEVEL
Static water level 100 feet below land surface
Artesian flow ____ G.P.M. 20 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A & H PUMP CO. Contractor
Address 5551 Hwy. 50 East #3 Carson City, Nevada 897 883-0459 883-40 885-1889

Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joe Butts
By driller performing actual drilling on site or contractor
Date 4/15/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627