

OFFICE USE ONLY
 Log No. 41047
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23531

1. OWNER WESTWINDS CONSTRUCTION ADDRESS AT WELL LOCATION 3D CURRANT CT
 MAILING ADDRESS GARDNERVILLE GARDNERVILLE

2. LOCATION SE 1/4 SE 1/4 Sec 36 T. 13 N. R. 20 E. DOUGLAS County
 PERMIT NO. 23-472-66 Parcel No. _____ Subdivision Name WILDFLOWER
Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MAND

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY w/COBBLES		0	28	28
SANDY CLAY		28	176	148
CLAY		176	212	36
SANDY CLAY		212	264	52
CLAY		264	280	16
SANDY CLAY		280	325	45
CLAY		325	369	44
SANDY CLAY		369	430	61
CLAY		430	487	57
SANDY CLAY		487	533	46
CLAY		533	542	9
SANDY CLAY		542	585	43
COARSE SAND	✓	585	594	9
SANDY CLAY		594	599	5
COARSE SAND	✓	599	617	18
SANDY CLAY		617	620	3

8. WELL CONSTRUCTION
 Depth Drilled 620 Feet Depth Cased 620 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 620 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>620</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 x 3/32
 From 580 feet to 620 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 620 feet

9. WATER LEVEL
 Static water level 255 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature WARM °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV
 Nevada contractor's license number 27673
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1726
 Division of Water Resources, the on-site driller
 Signed Pat J. Moore
 By driller performing actual drilling on site contractor
 Date 4/16/93

Date started 4/9 1993
 Date completed 4/16 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR</u>	<u>20+</u>	<u>-</u>	<u>4</u>

93 APR 27 AID 51
 STATE ENGINEERS OFFICE