

OFFICE ONLY  
 Log No. 41078  
 Permit No. 105  
 Basin. 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23529

1. OWNER MIKE ARETT ADDRESS AT WELL LOCATION 2834 ROMERO  
 MAILING ADDRESS GARDNERVILLE GARDNERVILLE

2. LOCATION SE 1/4 SW 1/4 Sec 26 T 14 N S R. 20 E DOUGLAS County  
 PERMIT NO. 21-240-34 JOHNSON LANE  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	8	8
SANDY CLAY w/ GRAVEL		8	73	65
SANDY CLAY		73	87	14
CLAY		87	102	15
SANDY CLAY		102	245	143
GRAY CLAY		245	286	41
SANDY CLAY w/ GRAVEL		286	312	26
SAND w/ SILT		312	349	37
COARSE SAND	✓	349	387	38
FRACTURED BASALT	✓	387	395	8

1993 APR 27 10:51 RECEIVED STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 395 Feet Depth Cased 395 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 310 Feet  
5 5/8 Inches 310 Feet 395 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>310</u>
<u>5</u>	<u>10</u>	<u>.188</u>	<u>310</u>	<u>395</u>

Perforations:  
 Type perforation FACTORY SLOTTED  
 Size perforation 3 X 3/32  
 From 290 feet to 310 feet  
 From 355 feet to 395 feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 310 feet

9. WATER LEVEL  
 Static water level 220 feet below land surface  
 Artesian flow — G.P.M. — P.S.I.  
 Water temperature COLD °F Quality GOOD

Date started 3/26, 1993  
 Date completed 4/3, 1993

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>12 +</u>	<u>—</u>	<u>4</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC Contractor  
 Address 7780 CURRY RD. Contractor  
FALLON, NV

Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726

Signed Art J. Moon  
 By driller performing actual drilling on site or Contractor  
 Date 4/4/93