

OFFICE USE ONLY  
 Log No. 41052  
 Permit No. 105  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23528

1. OWNER JOHN DECARLO CONST. ADDRESS AT WELL LOCATION 2620 KAYNE  
 MAILING ADDRESS GARDNERVILLE GARDNERVILLE

2. LOCATION SW 1/4 SW 1/4 Sec 34 T 14 N R 20 E DOUGLAS County  
 PERMIT NO. 21-201-09 JOHNSON LANE  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	58	58
SANDY CLAY w/GRAVEL		58	93	
CLAY		93	116	23
SANDY CLAY w/GRAVEL		116	129	13
SAND	✓	129	145	16
SANDY CLAY		145	156	11
CLAY		156	160	4

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:  
 Type perforation FACTORY SLOTTED  
 Size perforation 3 A 3/32  
 From 130 feet to 150 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 160 feet

1993 APR 27 AM 05:51  
 RECEIVED  
 STATE ENGINEERS OFFICE

Date started 3/19, 1993  
 Date completed 3/24, 1993

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>10+</u>	<u>-</u>	<u>1</u>

9. WATER LEVEL  
 Static water level 30 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDCO EXPLORATION, INC. Contractor  
 Address 7780 CURRY RD. Contractor  
FALLOON, NV  
 Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726  
 Signed Pat A. Moore  
 By driller performing actual drilling on site or contractor  
 Date 3/24/93