

Log No. 41063
 Permit No. _____
 Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10351

1. OWNER THOMAS FAGAN ADDRESS AT WELL LOCATION LOT 3 Blosser Ranch Rd
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 SW 1/4 Sec. 36 T 19S N/S R 52 E Nye County _____
 PERMIT NO. 27-171-32 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	7	7
Caliche		7	9	2
Clay		9	28	19
Caliche		28	30	2
Clay		30	57	27
Caliche	w.B	57	60	3
Clay		60	72	12
Caliche	w.B	72	74	2
Clay		74	94	20
Caliche	w.B	94	96	2
Clay		96	126	30
Caliche	w.B	126	128	2
Clay		128	140	12

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Factory Saw Cut
 Size perforation 1/8" V 3
 From 120 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

RECEIVED
 MAR 25 1993
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 2-22 1993
 Date completed 2-26 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 48 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HR 78 Box 80368 Contractor
Pahrump NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Fagan
 By driller performing actual drilling on site or contractor
 Date 3-14-93

