



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10856

1. OWNER Harold Hunt ADDRESS AT WELL LOCATION Lot 1 elina st  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SW 1/4 NE 1/4 Sec 16 T 19S N/S R 53 E Nye County  
 PERMIT NO. 29-212-04 Parcel No. Countryside place II Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy clay		0	8	8
caliche		8	10	2
clay		10	22	12
caliche		22	24	2
clay		24	54	30
caliche		54	56	2
clay		56	87	31
caliche		87	89	2
clay		89	112	23
caliche	WB	112	114	2
clay		114	129	15
caliche	WB	129	131	2
clay		131	156	25
caliche	WB	156	159	3
clay		159	182	23
caliche	WB	182	184	2
clay		184	191	7
caliche	WB	191	193	2
clay		193	198	5
caliche	WB	198	200	2

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 0 Feet 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>200</u>

Perforations:  
 Type perforation Factory Saw cut  
 Size perforation 1 1/8 x 3  
 From 190 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

RECEIVED  
 JUN 29 1993

Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 6-7 1993  
 Date completed 6-11 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level 98 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling Contractor  
 Address HER 74 Box 80358 Contractor  
Rahcamp NV 89041  
 Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed Thomas De...  
 By driller performing actual drilling on site or contractor  
 Date 6-19-93