WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41795
Permit No.
Basin 66

NOTICE OF INTENT NO.

1. OWNER GOLD FIELDS OPER. CO. -CHIMNEY CREEK
MAILING ADDRESS P. O. BOX 69
GOLCONDA, NV 89414

ADDRESS AT WELL LOCATION 35 MILES NE OF GOLCONDA, NV

2. LOCATION NW ¼ NW ¼ Sec. 30 T. 39N N/S R. 43E E. HUMBOLDT County
PERMIT NO. M/O-473-A Hydro # (Issued by Water Resources) 7 (Parcel No.) Exploration Hole # SEE-806 (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	385	385
Altered Basalt		385	405	20
Siltstone		405	420	15
Altered Basalt		420	680	260
Siltstone		680	705	25
Black Shale		705	775	70
Altered Basalt		775	790	15
Cherty Shale		790	910	120
Altered Basalt		910	960	50
Cherty Shale		960	1000	40

'93 MAY 26 A1:53
RECEIVED
STATE ENGINEERS OFFICE

Date started May 3, 1993
Date completed May 7, 1993

7. WELL TEST DATA – NONE –
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 1000 Feet Depth Cased 480 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
5¼ Inches		0 Feet	1000 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1" PVC		Schedule 40	0	480

Perforations:
Type perforation Factory
Size perforation
From 440 feet to 480 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 304' to surface
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 304 feet to 678 feet

9. WATER LEVEL
Static water level 317 feet below land surface
Artesian flow NONE G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was ~~drilled~~ completed under my supervision and the report is true to the best of my knowledge.

Name
Contractor

Address
Contractor

Nevada contractor's license number issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1255

Signed David L. Gillmore
By driller performing actual drilling on site or contractor

Date 5/19/93

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627