

OFFICE USE ONLY
 Log No. 7760
 Permit No. 087
 Basin RI211
 NOTICE OF INTENT NO. 7765

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Lee Bros' Leasing ADDRESS AT WELL LOCATION 550 Kretzke Lane
 MAILING ADDRESS 1150 Mt. Rose Street Reno NV 89509 Reno NV
 2. LOCATION SW 1/4 SW 1/4 Sec 7 T. 19 S. R. 20 E Washoe County
 PERMIT NO. MO 489 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
The well was found to be in very good condition. Being only a dry upper well we perforated the bottom and pressure grouted to the top. To minimize damage to the new aquifer getting lot we didn't disturb the cherty vault, we simply finished the top with concrete mix.				
The mix we used for grouting was a ratio of 6 gallons of water per bag of type I-II portland cement and we used about one and one half barrels pressure grouting from the bottom of the well on up.				

8. WELL CONSTRUCTION
 Depth Drilled 30 Feet Depth Cased 30 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
5 Inches 0 Feet 30 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>AVC</u>	<u>Sch. 40</u>	<u>0</u>	<u>30</u>

Perforations:
 Type perforation Factory Slot
 Size perforation .020 Inch
 From _____ feet to _____ feet
 From 5 feet to 30 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 4 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 4 feet to 30 feet

9. WATER LEVEL
 Static water level N/A feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Andrew Driller
 Address 1635 Beller RD Reno NV 89509
 Nevada contractor's license number issued by the State Contractor's Board 34525
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
 Signed [Signature]
 Date 5-19-72

7. WELL TEST DATA
 TEST METHOD: Bailer Pump Air Lift
 G.P.M. Draw Down (Feet Below Static) Time (Hours)
N/A